	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
UNITED STATES OF AMERICA							
ALABAMA							
Alexander City	660	96	94	93	79	78	77
Anniston	599	96	94	93	79	78	77
Auburn	730	98	96	95	80	79	78
Burmingham	610	97	94	93	79	78	77
Decatur	580	97	95	94	79	78	77
Dothan	321	97	95	94	81	80	79
Florence	528	97	95	94	79	78	77
Gadsden	570	96	94	93	78	77	76
Huntsville	619	97	95	94	78	77	76
Mobile	211	95	93	91	80	79	79
Mobile	119	96	94	93	80	79	79
Montgomery	195	98	95	93	80	79	78
Selma-Craig AFB	207	98	96	94	81	80	79
Talladega	565	97	95	94	79	78	77
Tuscaloosa	170	98	96	95	81	80	79
ALASKA							
Anchorage	90	73	70	67	63	61	59
Barrow	22	58	54	50	54	51	48
Fairbanks	436	82	78	75	64	63	61
Juneau	17	75	71	68	66	64	62
Kodiak	21	71	66	63	62	60	58
Nome	13	66	62	59	58	56	54
ARIZONA							
Douglas	4098	100	98	96	70	69	68
Flagstaff	6973	84	82	80	61	60	59
Fort Huachuca	4664	95	93	91	69	68	67
Kingman	3446	103	100	97	70	69	69
Nogales	3800	100	98	96	72	71	70
Phoenix	1117	108	106	104	77	76	75
Prescott	5014	96	94	91	67	66	65
Tucson	2584	105	102	100	74	73	72
Winslow	4880	97	95	92	66	65	64
Yuma	199	111	109	107	79	78	77
ARKANSAS							
Blytheville AFB	264	98	96	93	80	79	78
Camden	116	99	97	96	81	80	79
El Dorado	252	98	96	95	81	80	79
Fayetteville	1253	97	95	93	77	76	75
Fort Smith	449	101	99	96	79	78	77
Hot Springs Nat Pk	710	99	97	96	79	78	77
Jonesboro	345	98	96	95	80	79	78
Little Rock	257	99	96	94	80	79	78
Pine Bluff	204	99	96	95	81	80	79
Texarkana	361	99	97	96	80	79	78



Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

Wet/Dry Bulb Reference Chart

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
CALIFORNIA							
Bakersfield	495	103	101	99	72	71	70
Barstow	2142	104	102	99	73	72	71
BlytheAP	390	111	109	106	78	77	76
Burbank	699	97	94	91	72	70	69
Chico	205	102	100	97	71	70	69
Concord	195	96	92	88	69	67	66
Covina	575	100	97	94	73	72	71
Crecent City	50	72	69	65	61	60	59
Downey	116	93	90	87	72	71	70
El Cajon	525	98	95	92	74	73	72
El Centro	-30	111	109	106	81	80	79
Escondido	660	95	92	89	73	72	71
Eureka / Arcate	217	67	65	63	60	59	58
Fairfield-Travis AFB	72	98	94	90	71	69	67
Fresno	326	101	99	97	73	72	71
Hamilton AFB	3	89	85	81	71	68	66
Laguna Beach	35	83	80	77	69	68	67
Livermore	545	99	97	94	70	69	68
Lompoc, Vanderburg AFB	552	82	79	76	65	63	61
Long Beach	34	87	84	81	72	70	69
Los Angeles	99	86	83	80	69	68	67
Los Angeles	312	94	90	87	72	70	69
Merced-Castle AFB	178	102	99	96	73	72	70
Modesto	91	101	98	96	72	71	70
Monterey	38	82	79	76	64	63	61
Napa	16	94	92	89	69	68	67
Needles	913	112	110	107	76	75	74
Oakland	3	85	81	77	65	63	62
Oceanside	30	84	81	78	69	68	67
Ontario	995	100	97	94	72	71	70
Oxnard AFB	43	84	80	78	70	69	67
Palmdale	2517	103	101	98	70	68	67
Palm Springs	411	110	108	105	79	78	77
Pasadena	864	96	93	90	72	70	69
Petaluma	27	94	90	87	70	68	67
Pamona	871	99	96	93	73	72	71
Redding	495	103	101	98	70	69	67
Redlands	1318	99	96	93	72	71	70
Richmond	55	85	81	77	66	64	63
Riverside-March AFB	1511	99	96	94	72	71	69
Sacramento	17	100	97	94	72	70	69
Salinas	74	87	85	82	67	65	64
San Bernadino, Norton AFB	1125	101	98	96	75	73	71
San Diego	19	86	83	80	71	70	68
San Fernando	977	100	97	94	73	72	71

Prices in this book are subject to change. For updated pricing, please call us at (877)-243-3945 or visit us online at www.CoolingTowerDepot.com

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
CALIFORNIA (continued)							
San Francisco	8	83	79	75	65	63	62
San Francisco	52	80	77	73	64	62	61
San Jose	70	90	88	85	69	67	65
San Luis Obispo	315	89	85	82	65	64	63
Santa Ana	115	92	89	86	72	71	70
Santa Barbara	100	87	84	81	67	66	65
Santa Cruz	125	87	84	80	66	65	63
Santa Maria	238	87	84	80	67	66	65
COLORADO							
Denver	5280	93	91	89	63	62	61
Fort Collins	5001	91	89	86	63	62	61
Grand Junction	4849	96	94	92	64	63	62
Greeley	4648	94	92	89	65	64	63
La Junta	4188	97	95	93	72	71	69
Leadville	10177	76	73	70	56	55	54
Pueblo	4639	96	94	92	68	67	66
Sterling	3939	95	93	90	67	66	65
Trinidad	5746	93	91	89	66	65	64
CONNECTICUT							
Bridgeport,	7	90	88	85	77	76	75
Hartford, Brainard Field	15	90	88	85	77	76	74
New Haven	6	88	86	83	77	76	75
New London	60	89	86	83	77	75	74
Norwalk	37	91	89	86	77	76	75
Norwich	20	88	86	83	77	76	75
Waterbury	605	90	88	85	77	76	75
Windsor Locks, Bradley Field	169	90	88	85	76	75	73
DELAWARE							
Dover AFB	38	93	90	88	79	78	77
Wilmington	78	93	90	87	79	77	76
DISTRICT COLUMBIA							
Andrews AFB	279	94	91	88	79	77	76
Washington National	14	94	92	90	78	77	76
FLORIDA							
Belle Glade	16	93	91	90	80	79	79
Cape Kennedy	16	90	89	88	81	80	79
Daytona Beach	31	94	92	91	81	80	79
Fort Lauderdale	13	91	90	89	81	80	79
Fort Myers	13	94	92	91	80	80	79
Fort Pierce	10	93	91	90	81	80	79
Gainesville	155	96	94	93	80	79	79
Jacksonville	24	96	94	92	80	79	79
Key West	6	90	89	88	80	79	79
Lakeland	214	95	93	91	80	79	78
Miami	7	92	90	89	80	79	79
Miami Beach	9	91	89	88	80	79	79
Ocala	86	96	94	93	80	79	79

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com
Free! the industries only Online Cooling Tower Design Program With Pricing. Beat That. Free!

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

Wet/Dry Bulb Reference Chart

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
FLORIDA (continued)							
Orlando	106	96	94	93	80	79	78
Panama City, Tyndall AFB	22	92	91	90	81	80	80
Pensacola	13	92	90	89	82	81	80
St Augustine	15	94	92	90	81	80	79
St Petersburg	35	93	91	90	81	80	79
Sanford	14	95	93	92	80	79	79
Sarasota	30	93	91	90	80	80	79
Tallahassee	58	96	94	93	80	79	79
Tampa	19	92	91	90	81	80	79
West Palm Beach	15	92	91	89	81	80	80
GEORGIA							
Albany, Turner AFB	224	98	96	94	80	79	78
Americus	476	98	96	93	80	79	78
Athens	700	96	94	91	78	77	76
Monltrie	340	97	95	93	80	79	78
Rome	637	97	95	93	78	77	76
Savannah-Travis	52	96	94	92	81	80	79
Valdosta-Moody AFB	239	96	94	92	80	79	78
Waycross	140	97	95	93	80	79	78
HAWAII							
Hilo	31	85	83	82	74	73	72
Honolulu	7	87	85	84	75	74	73
Kaneohe	198	85	83	82	74	73	73
Wahaiwa	215	86	84	83	75	74	73
IDAHO							
Boise	2842	96	93	91	68	66	65
Burley	4180	95	93	89	68	66	64
Coeur d'Alene	2973	94	91	88	66	65	63
Idaho Falls	4730	91	88	85	65	64	62
Lewiston	1413	98	96	93	67	66	65
Moscow	2660	91	89	86	64	63	61
Mountan Home AFB	2992	99	96	93	68	66	64
Pocatello	4444	94	91	88	65	63	62
Twin Falls	4148	96	94	91	66	64	63
ILLINOIS							
Aurora	744	93	91	88	78	77	75
Belleville, Scott AFB	447	97	95	92	79	78	77
Bloominton	775	94	92	89	79	78	77
Carbondale	380	98	96	94	80	79	78
Champaign / Urbana	743	96	94	91	79	78	77
Chicago Midway	610	95	92	89	78	76	75
Chicago, O'Hare	658	93	90	87	77	75	74
Chicago, C O	594	94	91	88	78	76	75
Danvme	558	96	94	91	79	78	76
Decatur	670	96	93	91	79	78	77
Divon	696	93	91	89	78	77	76
Elgin	820	92	90	87	78	76	75

Prices in this book are subject to change. For updated pricing, please call us at (877)-243-3945 or visit us online at www.CoolingTowerDepot.com

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
ILLINOIS (continued)							
Freeport	780	92	90	87	78	77	75
Galesburg	771	95	92	89	79	78	76
Greenville	563	96	94	92	79	78	77
Joliet	588	94	92	89	78	77	75
Kankakee	625	94	92	89	78	77	76
La Salle/Peru	520	94	93	90	78	77	76
Macomb	702	95	93	90	79	78	77
Moline	582	94	91	88	79	77	76
Mt Vernon	500	97	95	92	79	78	77
Peoria	652	94	92	89	78	77	76
Quincy	762	97	95	92	80	79	77
Rantoul, Chanute AFB	740	94	92	89	78	77	76
Springfield	587	95	92	90	79	78	77
Waukegan	680	92	90	87	77	76	75
INDIANA							
Anderson	847	93	91	88	78	77	76
Bedford	670	95	93	90	78	77	76
La Porte	810	93	91	88	77	76	74
Marion	791	93	91	88	78	76	75
Muncie	955	93	91	88	78	77	75
Peru, Bunker Hill AFB	804	91	89	86	77	76	74
Richmond	1138	93	91	88	78	77	75
Shelbyville	765	94	92	89	78	77	76
South Bend	773	92	89	87	77	76	74
Terre Haute	601	95	93	91	79	78	77
Valparaiso	801	92	90	87	78	76	75
Vincennes	420	96	94	91	79	78	77
IOWA							
Ames	1004	94	92	89	79	78	76
Burlington	694	95	92	89	80	78	77
Cedar Rapids	863	92	90	87	78	76	75
Clinton	595	92	90	87	78	77	76
Council Bluffs	1210	97	94	91	79	78	76
Des Moines	948	95	92	89	79	77	76
Debuque	1065	92	90	87	78	76	75
Fort Dodge	1111	94	92	89	78	77	75
Iowa City	645	94	91	88	79	77	76
Keokuk	526	95	93	90	79	78	77
Marshalltown	898	93	91	88	79	77	76
Mason City	1194	91	88	85	77	75	74
Newton	946	95	93	90	79	77	76
Ottumwa	842	95	93	90	79	78	76
Sioux City	1095	96	93	90	79	77	76
Waterloo	868	91	89	86	78	76	75



Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

Wet/Dry Bulb Reference Chart

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
KANSAS							
Atchison	945	97	95	92	79	78	77
Chanute	977	99	97	95	79	78	77
Dodge City	2594	99	97	95	74	73	72
El Dorado	1282	101	99	96	78	77	76
Emporia	1209	99	97	94	78	77	76
Garden City	2882	100	98	96	74	73	72
Goodland	3645	99	96	93	71	70	69
Great Bend	1940	101	99	96	77	76	75
Hutchinson	1524	101	99	96	77	76	75
Liberal	2838	102	100	99	74	73	71
Manhattan, Fort Riley	1076	101	98	95	79	78	77
Parsons	908	99	97	94	79	78	77
Russell	1864	102	100	97	78	76	75
Salina	1271	101	99	96	78	76	75
Topeka	877	99	96	94	79	78	77
Wichita	1321	102	99	96	77	76	75
KENTUCKY							
Ashland	551	94	92	89	77	76	75
Bowling Green	535	97	95	93	79	78	77
Corbin	1175	93	91	89	79	77	76
Covington	869	93	90	88	77	76	75
Hopkinsville, Campbell AFB	540	97	95	92	79	78	77
Lexington	979	94	92	90	78	77	76
Louisville	474	96	93	91	79	78	77
Madisonville	409	96	94	92	79	78	77
Owensboro	420	96	94	92	79	78	77
Paducah	398	97	95	94	80	79	78
LOUISIANA							
Alexandria	92	97	98	94	80	80	79
Baton Rouge	64	96	94	92	81	80	79
Bogalusa	103	96	94	93	80	79	78
Houma	13	94	92	91	81	80	79
Lafayette	38	95	93	92	81	81	80
Lake Charles	14	95	93	91	80	79	79
Minden	250	98	96	95	81	80	79
Monroe	78	98	96	95	81	81	80
Natchitoches	120	99	97	96	81	80	79
New Orleans	3	93	91	90	81	80	79
Shreveport	252	99	96	94	81	80	79
MAINE							
Augusta	350	88	86	83	74	73	71
Bangor, Dow AFB	162	88	85	81	75	73	71
Caribou	624	85	81	78	72	70	68
Lewiston	182	88	86	83	74	73	71
Millinocket	405	87	85	82	74	72	70
Portland	61	88	85	81	75	73	71
Waterville	89	88	86	82	74	73	71

Prices in this book are subject to change. For updated pricing, please call us at (877)-243-3945 or visit us online at www.CoolingTowerDepot.com

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
MARYLAND							
Baltimore	146	94	91	89	79	78	77
Baltimore	14	94	92	89	79	78	77
Cumberland	945	94	92	89	76	75	74
Frederick	294	94	92	89	78	77	76
Hagerstown	660	94	92	89	77	76	75
Salisbury	52	92	90	87	79	78	77
MASSACHUSETTS							
Boston	15	91	88	85	76	74	73
Clinton	398	87	85	82	75	74	72
Fall River	190	88	86	83	75	74	73
Framingham	170	91	89	86	76	74	73
Greenfield	10	86	84	81	74	73	72
Gloucester	205	89	87	84	75	74	73
Lawrence	57	90	88	85	76	74	72
Lowell	90	91	89	86	76	74	72
New Bedford	70	86	84	81	75	73	72
Pittsfield	1170	86	84	81	74	72	71
Springfield, Westover AFB	247	91	88	85	76	74	73
Taunton	20	88	86	83	76	75	74
Wocester	986	89	87	84	75	73	71
MICHIGAN							
Adrian	754	93	91	88	76	75	74
Alpena	689	87	85	82	74	73	71
Battle Creek	939	92	89	86	76	74	73
Benton Harbor	649	90	88	85	76	74	73
Detroit Met CAP	633	92	88	85	76	75	74
Escanaba	594	82	80	77	73	71	69
Flint	766	89	87	84	76	75	74
Grand Rapids	681	91	89	86	76	74	73
Holland	612	90	88	85	76	74	73
Jackson	1003	92	89	86	76	75	74
Kalamazoo	930	92	89	86	76	75	74
Lansing	852	89	87	84	76	75	73
Marquette	677	88	86	83	73	71	69
Mt Pleasant	796	89	87	84	75	74	73
Muskegon	627	87	85	82	75	74	73
Pontiac	974	90	88	85	76	75	73
Port Huron	586	90	88	85	76	74	73
Saginaw	662	88	86	83	76	75	73
Sault Ste Marie	721	83	81	78	73	71	69
Traverse City	618	89	86	83	75	73	72
Ypsilanti	777	92	89	86	76	74	73
MINNESOTA							
Albert Lea	1235	91	89	86	77	76	74
Alexandria	1421	90	88	85	76	74	72
Bemidji	1392	87	84	81	73	72	71

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com
Free! the industries only Online Cooling Tower Design Program Free!
With Pricing. Beat That.

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

Wet/Dry Bulb Reference Chart

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
MINNESOTA (continued)							
Brainerd	1214	88	85	82	74	73	72
Duluth	1426	85	82	79	73	71	69
Faribault	1190	90	88	85	77	75	74
Fergus Falls	1210	92	89	86	75	74	72
International Falls	1179	86	82	79	72	69	68
Manakato	785	91	89	86	77	75	74
Minneapolis / St Paul	822	92	89	86	77	75	74
Rochester	1297	90	88	85	77	75	74
St Cloud	1034	90	88	85	77	75	73
Virginia	1435	86	83	80	73	71	69
Willmar	1133	91	88	85	77	75	73
Winona	652	91	89	86	77	76	74
MISSISSIPPI							
Biloxi, Keesler AFB	25	93	92	90	82	81	80
Clarksdale	178	98	96	95	81	80	79
Columbus AFB	224	97	95	93	79	79	78
Greenville AFB	139	98	96	94	81	80	79
Greenwood	128	98	96	94	81	80	79
Hattiesburg	200	97	95	94	80	79	78
Jackson	330	98	96	94	79	78	78
Laurel	264	97	95	94	80	79	78
McComb	458	96	94	93	80	79	79
McComb	294	97	95	94	80	79	78
Meridian	168	96	94	93	80	80	79
Tupelo	289	98	96	95	80	79	78
Vicksburg	234	97	95	94	80	80	79
MISSOURI							
Cape Girardeau	330	98	96	94	80	79	78
Columbia	778	97	95	92	79	78	77
Farmington	928	97	95	93	79	78	77
Hannibal	489	96	94	91	79	78	77
Jefferson City	640	97	95	93	79	78	77
Joplin	982	97	95	93	79	78	77
Kansas City	742	100	97	94	79	77	76
KirksvilleAP	966	96	94	91	79	78	77
Mexico	775	96	94	91	79	78	77
Moberly	850	96	94	91	79	78	77
Poplar Bluff	322	98	96	94	80	79	78
Rolla	1202	97	95	93	79	78	77
St Joseph	809	97	95	92	79	78	77
St Louis	535	98	95	92	79	78	77
St Louis	465	96	94	92	79	78	77
Sedalia, Whiteman AFB	838	97	94	92	79	77	76
Sikeston	318	98	96	94	80	79	78
Springfield	1265	97	94	91	78	77	76

Prices in this book are subject to change. For updated pricing, please call us at (877)-243-3945 or visit us online at www.CoolingTowerDepot.com

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
MONTANA							
Billings	3567	94	91	88	68	66	65
Bozeman	4856	88	85	82	61	60	59
Butte	5526	86	83	80	60	59	57
Cut Bank A P	3838	89	86	82	65	63	61
Glasgow	2277	96	93	89	69	67	65
Glendive	2076	96	93	90	71	69	68
Great Falls	3664	91	88	85	64	63	61
Havre	2488	91	87	84	66	64	63
Helena	3893	90	87	84	65	63	61
Kalispell	2965	88	84	81	65	63	2
Lewiston	4132	89	86	83	65	63	62
Livingston	4653	91	88	85	63	62	61
Miles City	2629	97	94	91	71	69	68
Missoula	3200	92	89	86	65	63	61
NEBRASKA							
Beatrice	1235	99	97	94	78	77	76
Chadron	3300	97	95	92	72	70	69
Columbus	1442	98	96	93	78	76	75
Fremont	1203	99	97	94	78	77	76
Grand Island	1841	98	95	92	76	75	74
Hastings	1932	98	96	94	77	75	74
Kearney	2146	97	95	92	76	75	74
Lincoln	1150	100	96	93	78	77	76
McCook	2565	99	97	94	74	72	71
Norfolk	1532	97	95	92	78	76	75
North Platte	2779	97	94	90	74	73	72
Omaha	978	97	94	91	79	78	76
Scottsbluff	3950	96	94	91	70	69	67
Sidney	4292	95	92	89	70	69	67
NEVADA							
Carson City	4675	93	91	88	62	61	60
ElkoAP	5075	94	92	90	64	62	61
ElyAP	6257	90	88	86	60	59	58
Las Vegas	2162	108	106	104	72	71	70
Lovelock	3900	98	96	93	65	64	62
Reno	4404	95	92	90	64	62	61
Reno	4490	94	92	89	64	62	61
Tonopah	5426	95	92	90	64	63	62
Winnemucca	4299	97	95	93	64	62	61
NEW HAMPSHIRE							
Berlin	1110	87	85	82	73	71	70
Claremont	420	89	87	84	74	73	72
Concord	339	91	88	85	75	73	72
Keene	490	90	88	85	75	73	72
Laconia	505	89	87	84	74	73	72
Manchester, Grenier AFB	253	92	89	86	76	74	73
Portsmouth, Pease AFB	127	88	86	83	75	73	72



Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

Wet/Dry Bulb Reference Chart

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
NEW JERSEY							
Atlantic City	11	91	88	85	78	77	76
Long Branch	20	93	91	88	77	76	75
Newark	11	94	91	88	77	76	75
New Brunswick	86	91	89	86	77	76	75
Paterson	100	93	91	88	77	76	75
Phillipsburg	180	93	91	88	77	76	75
Trenton	144	92	90	87	78	77	76
Vineland	95	93	90	87	78	77	76
NEW MEXICO							
Alamagordo, Holloman AFB	4070	100	98	96	70	69	68
Albuquerque	5310	96	94	92	66	65	64
Artesia	3375	101	99	97	71	70	69
Carlsbad	3234	101	99	97	72	71	70
ClovisAP	4279	99	97	95	70	69	68
Farmington	5495	95	93	91	66	65	64
Gallup	6465	92	90	87	64	63	62
Grants	6520	91	89	86	64	63	62
HobbsAP	3664	101	99	96	72	71	70
Las Cruces	3900	102	100	97	70	69	68
Las Alamos	7410	88	86	83	64	63	62
Raton	6379	92	90	88	66	65	64
Roswell, Walker AFB	3643	101	99	97	71	70	69
Santa Fe	7045	90	88	85	65	63	62
Silver City	5373	95	93	91	68	67	66
Socorro	4617	99	97	94	67	66	65
Tucumacari	4053	99	97	95	71	70	69
NEW YORK							
Albany	277	91	88	85	76	74	73
Albany C O	19	91	89	86	76	74	73
Auburn	715	89	87	84	75	73	72
Batavia	900	89	87	84	75	74	72
Binghamton	858	91	89	86	74	72	71
Buffalo	705	88	86	83	75	73	72
Cortland	1129	90	88	85	75	73	72
Dunkirk	590	88	86	83	75	74	72
Elmira	860	92	90	87	75	73	72
Geneva	590	91	89	86	75	73	72
Glens Falls	321	88	86	83	74	72	71
Gloversville	770	89	87	84	75	73	71
Hornell	1325	87	85	82	74	72	71
Ithaca	950	91	88	85	75	73	72
Jamestown	1390	88	86	83	75	73	72
Kingston	279	92	90	87	76	74	73
Lockport	520	87	85	82	75	74	72
Massena	202	86	84	81	75	74	72
Newburgh-Stewart AFB	460	92	89	86	78	76	74
NYC-Central Park	132	94	91	88	77	76	75

Prices in this book are subject to change. For updated pricing, please call us at (877)-243-3945 or visit us online at www.CoolingTowerDepot.com

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
NEW YORK (continued)							
NYC-Kennedy	16	91	87	84	77	76	75
NYC-LaGuardia	19	93	90	87	77	76	75
Niagara Falls	596	88	86	83	75	74	73
Olean	1420	87	85	82	74	72	71
Oneonta	1150	89	87	84	74	72	71
Oswego	300	86	84	81	75	74	72
Plattsburg AFB	165	86	84	81	74	73	71
Poughkeepsie	103	93	90	87	77	75	74
Rochester	543	91	88	85	75	74	72
Rome-Griffiss AFB	515	90	87	84	76	74	73
Sschenectady	217	90	88	85	75	73	72
Suffolkunty AFB	57	87	84	81	76	75	74
Syracuse	424	90	87	85	76	74	73
Utica	714	89	87	84	75	73	72
Watertown	497	86	84	81	75	74	72
NORTH CAROLINA							
Asheville	2170	91	88	86	75	74	73
Charlotte	735	96	94	92	78	77	76
Durham	406	94	92	89	78	77	76
Elizabeth City	10	93	91	89	80	79	78
Fayetteville, Pope AFB	95	97	94	92	80	79	78
Goldsboro, Seymour-Johnson AFB	88	95	92	90	80	79	78
Greensboro	897	94	91	89	77	76	75
Greenville	25	95	93	90	81	80	79
Henderson	510	94	92	89	79	78	77
Hickory	1165	93	91	88	77	76	75
Jacksonville	24	94	92	89	81	80	79
Lumberton	132	95	93	90	81	80	79
New Bern	17	94	92	89	81	80	79
Raleigh/Durham	433	95	92	90	79	78	77
Rocky Mount	81	95	93	90	80	79	78
Wilmington	30	93	91	89	82	81	80
Winston-Salem	967	94	91	89	77	76	75
NORTH DAKOTA							
Bismarck	1647	95	91	88	74	72	70
Devil's Lake	1471	93	89	86	73	71	69
Dickinson	2595	96	93	90	72	70	68
Fargo	900	92	88	85	76	74	72
Grand Forks	832	91	87	84	74	72	70
Jamestown	1492	95	91	88	75	73	71
Minot	1713	91	88	84	72	70	68
Williston	1877	94	90	87	71	69	67
OHIO							
Akron/Canton	1210	89	87	84	75	73	72
Ashtabula	690	89	87	84	76	75	74
Athens	700	93	91	88	77	76	75

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com
Free! the industries only Online Cooling Tower Design Program With Pricing. Beat That. Free!

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

Wet/Dry Bulb Reference Chart

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
OHIO (continued)							
Bowling Green	675	93	91	88	77	75	74
Cambridge	800	91	89	86	77	76	75
Chillicothe	638	93	91	88	77	76	75
Cincinnati	761	94	92	90	78	77	76
Cleveland	777	91	89	86	76	75	74
Columbus	812	92	88	86	77	76	75
Dayton	997	92	90	87	77	75	74
Defiance	700	93	91	88	77	76	74
Findlay	797	92	90	88	77	76	75
Fremont	600	92	90	87	76	75	74
Hamilton	650	94	92	90	78	77	76
Lancaster	920	93	91	88	77	76	75
Lima	860	93	91	88	77	76	75
Mansfield	1297	91	89	86	76	75	74
Marion	920	93	91	88	77	76	75
Middletown	635	93	91	88	77	76	75
Newark	825	92	90	87	77	76	75
Norwalk	720	92	90	87	76	75	74
Portsmouth	530	94	92	89	77	76	75
Sandusky	606	92	90	87	76	75	74
Springfield	1020	93	90	88	77	76	75
Steubenville	992	91	89	86	76	75	74
Toledo	676	92	90	87	77	75	74
Warren	900	90	88	85	75	74	73
Wooster	1030	90	88	85	76	75	74
Youngstown	1178	89	86	84	75	74	73
Zanesville	881	92	89	87	77	76	75
OKLAHOMA							
Ada	1015	102	100	98	79	78	77
Altus AFB	1390	103	101	99	77	76	75
Ardmore	880	103	101	99	79	78	77
Bartlesville	715	101	99	97	79	78	77
Chickasha	1085	103	101	99	77	76	75
Enid-Vance AFB	1287	103	100	98	78	77	76
Lawton	1108	103	101	98	78	77	76
McAlester	760	102	100	98	79	78	77
Muskogee	610	102	99	96	79	78	77
Norman	1109	101	99	97	78	77	76
Oklahoma City	1280	100	97	95	78	77	76
Ponca City	996	102	100	97	78	77	76
Seminole	865	102	100	98	78	77	76
Stillwater	884	101	99	97	78	77	76
Tulsa	650	102	99	96	79	78	77
Woodward	1900	103	101	98	76	74	73
OREGON							
Albany	224	91	88	84	69	67	65
Astoria	8	79	76	72	61	60	59

Prices in this book are subject to change. For updated pricing, please call us at (877)-243-3945 or visit us online at www.CoolingTowerDepot.com

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
OREGON (continued)							
Baker	3368	94	92	89	66	65	63
Bend	3599	89	87	84	64	62	61
Corvallis	221	91	88	84	69	67	65
Eugene	364	91	88	84	69	67	65
Grants Pass	925	94	92	89	68	66	65
Klamath Falls	4091	89	87	84	63	62	61
MedfordAP	1298	98	94	91	70	68	66
Pendleton	1492	97	94	91	66	65	63
Portland	21	89	85	81	69	67	66
Portland	57	91	88	84	69	68	67
Roseburg	505	93	91	88	69	67	65
Salem	195	92	88	84	69	67	66
The Dalles	102	93	91	88	70	68	67
PENNSYLVANIA							
Allentown	376	92	90	87	77	75	74
Altoona	1468	89	87	84	74	73	72
Butler	1100	91	89	86	75	74	73
Chambersburg	640	94	92	89	76	75	74
Erie A P	732	88	85	82	76	74	73
Harrisburg	335	92	89	86	76	75	74
Johnstown	1214	91	87	85	74	73	72
Lancaster	255	92	90	87	77	76	75
Meadville	1065	88	86	83	75	73	72
New Castle	825	91	89	86	75	74	73
Philadelphia	7	93	90	87	78	77	76
Pittsburgh	1137	90	87	85	75	74	73
Pittsburgh	749	90	88	85	75	74	73
Reading	226	92	90	87	77	76	75
Scranton/Wilkes-Barre	940	89	87	84	75	74	73
Statellege	1175	89	87	84	74	73	72
Sunbury	480	91	89	86	76	75	74
Union town	1040	90	88	85	75	74	73
Warren	1280	89	87	84	75	73	72
West Chester	440	92	90	87	77	76	75
Williamsport	527	91	89	86	76	75	74
York	390	93	91	88	77	76	75
RHODE ISLAND							
Newport	20	86	84	81	75	74	73
Providence	55	89	86	83	76	75	74
SOUTH CAROLINA							
Anderson	764	96	94	91	77	76	75
Charleston AFB	41	94	92	90	81	80	79
Charleston	9	95	93	90	81	80	79
Columbia	217	98	96	94	79	79	78
Florence	146	96	94	92	80	79	78
Georgetown	14	93	91	88	81	80	79



Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

Wet/Dry Bulb Reference Chart

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
SOUTH CAROLINA (continued)							
Greenville	957	95	93	91	77	76	75
Greenwood	671	97	95	92	78	77	76
Orangeburg	244	97	95	92	80	79	78
Rock Hill	470	97	95	92	78	77	76
Spartanburg	816	95	93	9'0	77	76	75
Sumter-Shaw AFB	291	96	94	92	80	79	78
SOUTH DAKOTA							
Aberdeen	1296	95	92	89	77	75	74
Brookings	1642	93	90	87	77	75	74
Huron	1282	97	93	90	77	75	74
Mitchell	1346	96	94	91	77	76	74
Pierre	1718	98	96	93	76	74	73
Rapid City	3165	96	94	91	72	71	69
SiouxFalls	1420	95	92	89	77	75	74
Watertown	1746	93	90	87	76	74	73
Yankton	1280	96	94	91	78	76	75
TENNESSEE							
Athens	940	96	94	91	77	76	75
Bristol-Tri City	1519	92	90	88	76	75	74
Chattanooga	670	97	94	92	78	78	77
Clarksville	470	98	96	94	79	78	77
Columbia	690	97	95	93	79	78	77
Dryersburg	334	98	96	94	80	79	78
Greenville	1320	93	91	88	76	75	74
Jackson	413	97	95	94	80	79	78
Knoxville	980	95	92	90	77	76	75
Memphis	263	98	96	94	80	79	78
Murfreesboro	608	97	94	92	79	78	77
Nashville	577	97	95	92	79	78	77
Tullahoma	1075	96	94	92	79	78	77
TEXAS							
Abeilene	1759	101	99	97	76	75	74
Alice	180	101	99	97	81	80	79
Amarillo	3607	98	96	93	72	71	70
Austin	597	101	98	96	79	78	77
Bay City	52	95	93	91	81	80	79
Beaumont	18	96	94	93	81	80	79
Beeville	225	99	97	96	81	80	79
Big Spring	2537	100	98	96	75	73	72
Brownsville	16	94	92	91	80	80	79
Brownwood	1435	102	100	98	76	75	74
Bryan	275	100	98	96	79	78	78
Corpus Christi	43	95	93	91	81	80	80
Corsicana	425	102	100	98	79	78	77
Dallas	481	101	99	97	79	78	78
Del Rio, Laughlin AFB	1072	101	99	98	79	77	76

Prices in this book are subject to change. For updated pricing, please call us at (877)-243-3945 or visit us online at www.CoolingTowerDepot.com

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
TEXAS (continued)							
Denton	655	102	100	98	79	78	77
Eagle Pass	743	106	104	102	80	79	78
El Paso	3918	100	98	96	70	69	68
Fort Worth	544	102	100	98	79	78	77
Galveston	5	91	89	88	82	81	81
Greenville	575	101	99	97	79	78	78
Harlingen	37	96	95	94	80	80	79
Houston	50	96	94	92	80	80	79
Houston	158	96	94	92	80	80	79
Huntsville	494	99	97	96	80	79	78
Killeen-Gray AFB	1021	100	99	97	78	77	76
Lamesa	2965	100	98	96	74	73	72
Laredo AFB	503	103	101	100	79	78	78
Longview	345	100	98	96	81	80	79
Lubbock	3243	99	97	94	73	72	71
Lufkin	286	98	96	95	81	80	79
McAllen	122	102	100	98	80	79	78
Midland	2815	‘100	98	96	74	73	72
Mineral Wells	934	102	100	98	78	77	76
Palestine	580	99	97	96	80	79	78
Pampa	3230	100	98	95	73	72	71
Pecos	2580	102	100	97	72	71	70
Plainview	3400	100	98	95	73	72	71
Port Arthur	16	94	92	91	81	80	80
San Angelo, Goodfellow AFB	1878	101	99	97	76	75	74
San Antonio	792	99	97	96	77	77	76
Sherman-Perrun AFB	763	101	99	97	79	78	77
Snyder	2325	102	100	97	75	74	73
Temple	675	101	99	97	79	78	77
Tyler	527	99	97	96	80	79	78
Vernon	1225	103	101	99	77	76	75
Victoria	104	98	96	95	80	79	79
Waco	500	101	99	98	79	78	78
Wichita Falls	994	103	100	98	77	76	75
UTAH							
Cedar City	5613	94	91	89	65	64	62
Logan	4775	93	91	89	66	65	63
Moab	3965	100	98	95	66	65	64
OgdenCO	4400	94	92	89	66	65	64
Price	5580	93	91	88	65	64	63
Provo	4470	96	93	91	67	66	65
Richfield	5300	94	92	89	66	65	64
St George	2899	104	102	99	71	70	69
Salt Lake City	4220	97	94	92	67	66	65
Vernal A P	5280	90	88	84	64	63	62



Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

Wet/Dry Bulb Reference Chart

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
VERMONT							
Barre	1120	86	84	81	73	72	70
Burlington	331	88	85	83	74	73	71
Rutland	620	87	85	82	74	73	71
VIRGINIA							
Charlottsville	870	93	90	88	79	77	76
Danville	590	95	92	90	78	77	76
Fredericksburg	50	94	92	89	79	78	76
Harrisonburg	1340	92	90	87	78	77	76
Lynchburg	947	94	92	89	77	76	75
Norfolk	26	94	91	89	79	78	78
Petersburg	194	96	94	91	80	79	78
Richmond	162	96	93	91	79	78	77
Roanoke	1174	94	91	89	76	75	74
Staunton	1480	92	90	87	78	77	75
Winchester	750	94	92	89	78	76	75
WASHINGTON							
Aberdeen	12	83	80	77	62	61	60
Bellingham	150	76	74	71	67	65	63
Bremerton	162	85	81	77	68	66	65
Ellensburg	1729	91	89	86	67	65	63
Everett-Paine AFB	598	82	78	74	67	65	63
Kennewick	392	98	96	93	69	68	66
Longview	12	88	86	83	68	66	65
Moses Lake, Larson AFB	1183	96	93	90	68	66	65
Olympia	190	85	83	80	67	65	63
Port Angeles	99	75	73	70	60	58	57
Seattle- Boeing Fid	14	82	80	77	67	65	64
Seattle	14	81	79	76	67	65	64
Seattle- Tacoma	386	85	81	77	66	64	63
Spokane	2357	93	90	87	66	64	63
Tacoma-McChord AFB	350	85	81	78	68	66	64
Walla Walla	1185	98	96	93	69	68	66
Wenatchee	634	95	92	89	68	66	64
Yakima	1061	94	92	89	69	67	65
WEST VIRGINIA							
Beckley	2330	91	88	86	74	73	72
Bluefield	2850	88	86	83	74	73	72
Charleston	939	92	90	88	76	75	74
Clarksburg	977	92	90	87	76	75	74
ElkinsAP	1970	87	84	82	74	73	72
Huntington	565	95	93	91	77	76	75
Martinsburg	537	96	94	91	78	77	76
Morgantown	1245	90	88	85	76	74	73
Parkersburg	615	93	91	88	77	76	75
Wheeling	659	91	89	86	76	75	74

Prices in this book are subject to change. For updated pricing, please call us at (877)-243-3945 or visit us online at www.CoolingTowerDepot.com

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
WISCONSIN							
Appleton	742	89	87	84	75	74	72
Ashland	650	85	83	80	73	71	69
Beloit	780	92	90	87	77	76	75
Eau Claire	888	90	88	85	76	74	72
Fond du Lac	760	89	87	84	76	74	73
Green Bav	683	88	85	82	75	73	72
La Crosse	652	90	88	85	78	76	75
Madison	858	92	88	85	77	75	73
Manitowoc	660	88	86	83	75	74	72
Marinette	605	88	86	83	74	72	70
Milwaukee	672	90	87	84	77	75	73
Racine	640	90	88	85	77	75	73
Sheboygan	648	89	87	84	76	74	72
Stevens Point	1079	89	87	84	75	73	71
Waukesha	860	91	89	86	77	75	74
Wausau	1196	89	86	83	74	72	70
WYOMING							
Casper	5319	92	90	87	63	62	60
Cheyenne	6126	89	86	83	63	62	61
Cody A P	5090	90	87	84	61	60	59
Evanston	6860	84	82	79	58	57	56
Lander	5563	92	90	87	63	62	60
Laramie	7266	82	80	77	61	59	58
Newcastle	4480	92	89	86	68	67	66
Rawlins	6736	86	84	81	62	61	60
Rock Springs	6741	86	84	82	58	57	56
Sheridan	3942	95	92	89	67	65	64
Torrington	4098	94	92	89	68	67	66
CANADA							
ALBERTA							
Calgary	3540	87	85	82	66	64	63
Edmonton	2219	86	83	80	69	67	65
Grand Prarie	2190	84	81	78	66	64	63
Jasper	3480	87	84	81	66	64	63
Lethbridge	3018	91	85	85	68	66	64
McMurray	1216	87	84	81	69	67	65
Medicine Hat	2365	96	93	90	72	69	67
Red Deer	2965	88	86	83	67	65	64
BRITISH COLUMBIA							
Dauson Creek	2200	84	81	78	66	64	63
Fort Nelson	1230	87	84	81	66	64	63
Kamloops	1150	97	94	91	71	69	68
Nanimo	100	81	78	75	66	64	62
New Westminster	50	86	84	82	68	66	65

COOLING TOWER DEPOT
Free! the industries only Online Cooling Tower Design Program With Pricing. Beat That.
Free!

Copyright © 2009 Visit our web site at www.coolingtowerdepot.com for our full Terms and Conditions

Wet/Dry Bulb Reference Chart

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
BRITISH COLUMBIA	**(continued)**						
Penticton	1121	94	91	88	71	69	68
Prince George	2218	85	82	79	68	65	63
Prince Rupert	170	73	71	69	62	60	59
Trail	1400	94	91	88	70	68	67
Vancouver	16	80	78	76	68	66	65
Victoria C O	228	80	76	72	64	62	60
MANITOBA							
Brandon	1200	90	87	84	75	73	71
Churchill A P	115	79	75	72	68	66	63
Dauphin	999	89	86	83	74	72	70
Flin Flon	1098	85	81	78	71	69	67
Portage la Prairie	867	90	87	84	75	74	72
The Pas A P	894	85	81	78	73	71	69
Winnipeg	786	90	87	84	75	74	72
NEW BRUNSWICK							
Campbellton	25	87	84	81	74	71	69
Chatham A P	112	90	87	84	74	71	69
Edmundston	500	84	81	78	75	72	70
Fredericton	74	89	86	83	73	70	68
Moncton	248	88	85	82	74	71	69
Saint John	352	81	79	77	71	68	66
NEWFOUNDLAND							
Corner Brook	40	84	81	79	69	68	66
Gander	482	85	82	79	69	68	66
Goose Bay	144	86	81	77	69	67	65
St John's A P	463	79	77	75	69	68	66
Stephenville	44	79	76	74	69	68	66
NORTHWEST TERRITORIES							
Fort Smith	665	85	83	80	67	65	64
Frobisher Bay	68	63	59	56			
Inuvik	75	80	77	75	63	61	60
Resolute	209	54	51	49			
Yellowknife	682	78	76	74	65	63	62
NOVA SCOTIA							
Amherst	63	85	82	79	72	70	68
Halifax	136	83	80	77	69	68	67
KentvilleCO	50	86	83	80	72	70	69
New Glasgow	317	84	81	79	72	70	68
Sydney	197	84	82	80	72	70	68
TruroCO	77	84	81	79	72	70	69
Yarmouth	136	76	73	71	69	68	67
ONTARIO							
Belleville	250	89	86	84	77	75	73
Chatham	600	92	90	88	77	75	74
Cornwall	210	89	86	84	77	75	74
Fort William	644	86	83	80	72	70	68

Prices in this book are subject to change. For updated pricing, please call us at (877)-243-3945 or visit us online at www.CoolingTowerDepot.com

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
ONTARIO (continued)							
Hamilton	303	91	88	86	77	75	73
Kapuskasing	752	87	84	81	73	71	69
Kenora	1345	86	83	80	75	73	71
Kingston	300	85	82	80	77	75	73
Kitchener	1125	88	85	83	76	75	74
London	912	90	88	86	76	75	74
North Bay	1210	87	84	82	71	70	69
Oshawa	370	90	87	85	77	75	73
Ottawa	339	90	87	84	75	74	73
Owen Sound	597	87	84	82	74	72	71
Peterborough	648	90	87	85	76	74	73
St Catharines	325	91	88	86	77	75	73
Sarnia	625	92	90	88	76	74	73
Sault Ste Marie	675	88	85	83	72	70	68
Sudbury	850	89	86	84	72	70	69
Timmins	1100	90	87	84	73	71	69
Toronto	578	90	87	85	77	75	73
Windsor	637	92	90	88	77	75	74
PRINCE EDWARD ISLAND							
Charlottetown	186	84	81	79	72	70	68
Summerside	78	84	81	79	72	70	68
QUEBEC							
Bagotville	536	88	84	81	72	71	69
Chincoutimi	150	87	83	80	72	71	69
Drummondville	270	88	85	82	76	74	72
Granby	550	87	84	82	76	74	72
Hull	200	90	87	84	75	74	73
Mégantic	1362	84	81	78	75	73	71
Montréal	98	88	86	84	76	74	73
Québec	245	86	82	79	75	73	71
Rimouski	117	78	74	71	71	69	68
St Jean	129	87	85	83	76	74	73
St Jérôme	310	87	84	82	76	74	73
Sept Îles	190	80	78	75	66	64	63
Shawingan	306	88	85	83	76	74	72
Sherbrooke	595	87	84	81	75	73	71
Thetford Mines	1020	86	83	80	75	73	71
Trois Rivieres	200	88	85	82	76	74	72
Val d'Or	1108	88	85	82	72	71	69
Valleyfield	150	87	85	83	76	74	73
SASKATCHEWAN							
Estevan	1884	93	89	86	75	73	71
Moose Jaw	1857	93	89	86	73	71	69
North Battleford	1796	90	86	83	71	69	67
Prince Albert	1414	88	84	81	72	70	68
Regina	1884	92	88	85	73	71	69

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com
Free! the industries only Online Cooling Tower Design Program With Pricing. Beat That. Free!

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

Wet/Dry Bulb Reference Chart

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
SASKATCHEWAN (continued)							
Saskatoon	1645	90	86	83	71	69	67
Swift Current	2677	93	89	86	72	70	68
Yorkton	1653	89	85	82	74	72	70
YUKON TERRITORY							
Whitehorse	2289	78	75	72	62	60	59
OTHER COUNTRIES							
ADEN							
Aden	10	102	100	98	83	82	82
AFGHANISTAN							
Kabul	5955	98	96	93	66	65	64
ALGERIA							
Algiers	194	95	92	89	77	76	75
ARGENTINA							
Buenoes Aires	89	91	89	86	77	76	75
Córdoba	1388	100	96	93	76	75	74
Tucuman	1401	102	99	96	76	75	74
AUSTRALIA							
Adelaide	140	98	94	91	72	70	68
Alice Springs	1795	104	102	100	75	74	72
Brisbane	137	91	88	86	77	76	75
Darwin	88	94	93	91	82	81	81
Melbourne	114	95	91	86	71	69	68
Perth	210	100	96	93	76	74	73
Sydney	138	89	84	80	74	73	72
AUSTRIA							
Vienna	644	88	86	83	71	69	67
AZORES							
Lajes (Terceira)	170	80	78	77	73	72	71
BAHAMAS							
Nassau	11	90	89	88	80	80	79
BELGIUM							
Brussels	328	83	79	77	70	68	67
BERMUDA							
Kindley AFB	129	87	86	85	79	78	78
BOLIVIA							
La Paz	12001	71	69	68	58	57	56
BRAZIL							
Belem	42	90	89	87	80	79	78
Belo Horizonte	3002	86	84	83	76	75	75
Brasilia	3442	89	88	86	76	75	75
Curitiba	3114	86	84	82	75	74	74
Fortaleza	89	91	90	89	79	78	78
Porto Alegre	33	95	92	89	76	76	75
Recife	97	88	87	86	78	77	77
Rio de Janeiro	201	94	92	90	80	79	78
Salvador	154	88	87	86	79	79	78
Sao Paulo	2608	86	84	82	75	74	74

Prices in this book are subject to change. For updated pricing, please call us at (877)-243-3945 or visit us online at www.CoolingTowerDepot.com

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
BRITISH HONDURAS							
Belize	17	90	90	89	82	82	81
BULGARIA							
Sofia	1805	89	86	84	71	70	69
BURMA							
Mandalay	252	104	102	101	81	80	80
Rangoon	18	100	98	95	83	82	82
CAMBODIA							
Phnom Penh	36	98	96	94	83	82	82
CEYLON							
Colombo	24	90	89	88	81	80	80
CHILE							
Punta Arenas	26	68	66	64	56	55	54
Santiago	1706	90	89	88	71	70	69
Valparaiso	135	81	79	77	67	66	65
CHINA							
Chungking	755	99	97	95	81	80	79
Shanghai	23	94	92	90	81	81	80
COLOMBIA							
Baranquilla	44	95	94	93	83	82	82
Bogota	8406	72	70	69	60	59	58
Cali	3189	84	82	79	70	69	68
Medellin	4650	87	85	84	73	72	72
CONGO							
Brazzaville	1043	93	92	91	81	81	80
Kinasha	1066	92	91	90	81	80	80
Stanleyville	1370	92	91	90	81	80	80
CUBA							
Guantanamo Bay	21	94	93	92	82	81	80
Havana	80	92	91	89	81	81	80
CZECHOSLOVAKIA							
Prague	662	88	85	83	66	65	64
DENMARK							
Copenhagen	43	79	76	74	68	66	64
DOMINICAN REPUBLIC							
Santo Domingo	57	92	90	88	81	80	80
ECUADOR							
Quayaquil	20	92	91	89	80	80	79
Quinto	9446	73	72	71	63	62	62
EL SALVADOR							
San Salvador	2238	98	96	95	77	76	75
ETHIOPIA							
Addis Ababa	7753	84	82	81	66	65	64
Asmara	7628	83	81	80	65	64	63
FINLAND							
Helsinki	30	77	74	72	66	65	63



Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

Wet/Dry Bulb Reference Chart

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
FRANCE							
Lyon	938	91	89	86	71	70	69
Marseilles	246	90	87	84	72	71	69
Nantes	121	86	83	80	70	69	67
Nice	39	87	85	83	73	72	72
Paris	164	89	86	83	70	68	67
Strasbourg	465	86	83	80	70	69	67
FRENCH GUIANA							
Cayenne	20	92	91	90	83	83	82
GERMANY							
Berlin	187	84	81	78	68	67	66
Hamburg	66	80	76	73	68	66	65
Hannover	561	82	78	75	68	67	65
Mannheim	359	87	85	82	71	69	68
Munich	1729	86	83	80	68	66	64
GHANA							
Accra	88	91	90	89	80	79	79
GIBRALTAR							
Gibraltar	11	92	89	86	76	75	74
GREECE							
Athens	351	96	93	91	72	71	71
Thessaloniki	78	95	93	91	77	76	75
GREENLAND							
Nassarssuaq	85	66	63	61	56	54	52
GUATEMALA							
Guatemala City	4855	83	82	81	69	68	67
GUYANA							
Georgetown	6	89	88	87	80	79	79
HAITI							
Port au Prince	121	97	95	93	82	81	80
HONDURAS							
Tegucigalpa	3094	89	87	85	73	72	71
HONG KONG							
Hong Kong	109	92	91	90	81	80	80
HUNGARY							
Budapest	394	90	86	84	72	71	70
ICELAND							
Reykjavik	59	59	58	56	54	53	53
INDIA							
Ahmenabad	163	109	107	105	80	79	78
Bangalore	3021	96	94	93	75	74	74
Bombay	37	96	94	92	82	81	81
Calcutta	21	98	97	96	83	82	82
Madras	51	104	102	101	84	83	83
Nagpur	1017	110	108	107	79	79	78
New Delhi	703	110	107	105	83	82	82

Prices in this book are subject to change. For updated pricing, please call us at (877)-243-3945 or visit us online at www.CoolingTowerDepot.com

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
INDONESIA							
Djakarta	26	90	89	88	80	79	78
Kupang	148	94	93	92	81	80	80
Makassar	61	90	89	88	80	80	79
Medan	77	92	91	90	81	80	79
Palembang	20	92	91	90	80	79	79
Surabaya	10	91	90	89	80	79	79
IRAN							
Abadan	7	116	113	110	82	81	81
Meshed	3104	99	96	93	68	67	66
Tehran	4002	102	100	98	75	74	73
IRAQ							
Baghdad	111	113	111	108	73	72	72
Mosul	730	114	112	110	73	72	72
IRELAND							
Dublin	155	74	72	70	65	64	62
Shannon	8	76	73	71	65	64	63
ISRAEL							
Jerusalem	2485	95	94	92	70	69	69
Tel Aviv	36	96	93	91	74	73	72
ITALY							
Milan	341	89	87	84	76	75	74
Napels	220	91	88	86	74	73	72
Rome	377	94	92	89	74	73	72
IVORY COAST							
Abidjan	65	91	90	88	83	82	81
JAPAN							
Fukuoka	22	92	90	89	82	80	79
Sapporo	56	86	83	80	76	74	72
Tokyo	19	91	89	87	81	80	79
JORDAN							
Amman	2548	97	94	92	70	69	68
KENYA							
Nairobi	5971	81	80	78	66	65	65
KOREA							
Pyongyang	186	89	87	85	77	76	76
Seoul	285	91	89	87	81	79	78
LEBANON							
Beirut	111	93	91	90	78	77	76
LIBERIA							
Monrovia	75	90	89	88	82	82	81
LIBYA							
Bengasi	82	97	94	91	77	76	75
MADAGASCAR							
Tananarive	4531	86	84	83	73	72	71

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com
Free! the industries only Online Cooling Tower Design Program With Pricing. Beat That. Free!

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

Wet/Dry Bulb Reference Chart

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
MALAYSIA							
Kuala Lumpur	127	94	93	92	82	82	81
Penang	17	93	93	92	82	81	80
Singapore	33	92	91	90	82	81	80
MARTINIQUE							
Fort de France	13	90	89	88	81	81	80
MEXICO							
Guadalajara	5105	93	91	89	68	67	66
Merida	72	97	95	94	80	79	77
Mexico City	7575	83	81	79	61	60	59
Monterrey	1732	98	95	93	79	78	77
Vera Cruz	184	91	89	88	83	83	82
MOROCCO							
Casablanca	164	94	90	86	73	72	70
NEPAL							
Katmandu	4388	89	87	86	78	77	76
NETHERLANDS							
Amsterdam	5	79	76	73	65	64	63
NEW GUINEA							
Manokwari	62	89	88	87	82	81	81
Point Moresby	126	92	91	90	80	80	79
NEW ZEALAND							
Auckland	140	78	77	76	67	66	65
Christ Church	32	82	79	76	68	67	66
Wellington	394	76	74	72	66	65	64
NICARAGUA							
Managua	135	94	93	92	81	80	79
NIGERIA							
Lagos	10	92	91	90	82	82	81
NORWAY							
Bergen	141	75	74	73	67	66	65
Oslo	308	79	77	74	67	66	64
PAKISTAN							
Chittagong	87	93	91	89	82	81	81
Karachi	13	100	98	95	82	82	81
Labore	702	109	107	105	83	82	81
Peshwar	1164	109	106	103	81	80	79
PANAMA AND CANAL ZONE							
Panama City	21	93	92	91	81	81	80
PARAQUAY							
Asuneion	456	100	98	96	81	81	80
PERU							
Lima	394	86	85	84	76	75	74
PHILLIPPINES							
Manila	47	94	92	91	82	81	81
PORTUGAL							
Lisbon	313	89	86	83	69	68	67

Prices in this book are subject to change. For updated pricing, please call us at (877)-243-3945 or visit us online at www.CoolingTowerDepot.com

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
POLAND							
Krakow	723	84	81	78	68	67	66
Warsaw	394	84	81	78	71	70	68
PORTUGAL							
Lisbon	313	89	86	83	69	68	67
PUERTO RICO							
San Juan	82	89	88	87	81	80	7
SUMANIA							
Bucharest	269	93	91	89	72	71	70
SAUDI ARABIA							
Dhahran	80	111	110	108	86	85	84
Jedda	20	106	103	100	85	84	83
Riyadh	1938	110	108	106	78	77	76
SENEGAL							
Dakar	131	95	93	91	81	80	80
SOMALIA							
Mogadiscio	39	91	90	89	82	82	81
SOUTH AFRICA							
Capetown	55	93	90	86	72	71	70
Johannesburg	5463	85	83	81	70	69	69
Pretoria	4491	85	87	85	70	69	68
SOVIET UNION							
Alma Ata	2543	88	86	83	69	68	67
Archangel	22	75	71	68	60	58	57
Kalinigrad	23	83	80	77	67	66	65
Krasnoyarsk	498	84	80	76	64	62	60
Kiev	600	87	84	81	69	68	67
Kharkov	472	87	84	82	69	68	67
Kuibyshev	190	89	85	81	69	67	66
Leningrad	16	78	75	72	65	64	63
Minsk	738	80	77	74	67	66	65
Moscow	505	84	81	78	69	67	65
Odessa	214	87	84	82	70	69	68
Petropavlovsk	286	70	68	65	58	57	56
Rostov on Don	159	90	87	84	70	69	68
Sverdlovsk	894	80	76	72	63	62	60
Tashkent	1569	95	93	90	71	70	69
Tblisi	1325	87	85	83	68	67	66
Vladivostok	94	80	77	74	70	69	68
Volgograd	136	93	89	86	71	70	69
SPAIN							
Barcelona	312	88	86	84	75	74	73
Madrid	2188	93	91	89	71	69	67
Valencia	79	92	90	88	75	74	73



Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com

Wet/Dry Bulb Reference Chart

	Elevation	Design Dry Bulb			Design Wet Bulb		
	Ft	1%	2%	5%	1%	2%	5%
SUDAN							
Khartoum	1279	109	107	104	77	76	75
SURINAM							
Paramaribo	12	93	92	90	82	82	81
SWEDEN							
Stockholm	146	78	74	72	64	62	60
SWITZERLAND							
Zurich	1617	84	81	78	68	67	66
SYRIA							
Damascus	2362	102	100	98	72	71	70
TAIWAN							
Tainan	70	92	91	90	84	83	82
Taipei	30	94	92	90	83	82	81
TANZANIA							
Dar es Salaam	47	90	89	88	82	81	81
THAILAND							
Bangkok	39	97	95	93	82	82	81
TRINIDAD							
Port of Spain	67	91	90	89	80	80	79
TUNISIA							
Tunis	217	102	99	96	77	76	74
TURKEY							
Adana	82	100	97	95	79	78	77
Ankara	2825	94	92	89	68	67	66
Istanbul	59	91	88	86	75	74	73
Izmir	16	98	96	94	75	74	73
UNITED ARAB REPUBLIC							
Cairo	381	102	100	98	76	75	74
UNITED KINGDOM							
Belfast	24	74	72	69	65	64	62
Birmingham	535	79	76	73	66	64	63
Cardiff	203	79	76	73	64	63	62
Edinburgh	441	73	70	68	64	62	61
Glasgow	85	74	71	68	64	63	61
London	149	82	79	76	68	66	65
URUGUAY							
Montevideo	72	90	88	85	73	72	71
VENEZUELA							
Carcas	3418	84	83	81	70	69	69
Maracaibo	20	97	96	95	84	83	83
VIET NAM							
Da Nang	23	97	95	93	86	86	85
Hanoi	53	99	97	95	85	85	84
Saigon	30	93	91	89	85	84	83
YUGOSLAVIA							
Belgrade	453	92	89	86	74	73	72

Prices in this book are subject to change. For updated pricing, please call us at (877)-243-3945 or visit us online at www.CoolingTowerDepot.com

COOLING TOWER DEPOT
The Depot of All Cooling Towers
www.coolingtowerdepot.com

Copyright © 2009 All Rights Reserved All Transactions are subject to our full Terms and Conditions found at www.CoolingTowerDepot.com